

APPLIANCE TESTING CERTIFICATE

Certificate No.: 377

Instrument Serial No.:

1000-804/090309/1014

CLIENT AND LOCATION DETAILS

SCREAM ENTERTAINMENTS

SAME

NUNEATON
CV10 9LZ

TEST RESULTS

Asset ID	Description	Serial Number	Room	Test Date	Visual	Cont 1	Cont 2	Cont 3	Ins.	Oper.	Leak.	Extn.	Flash	Status
01101	ELSC1	ELSC1	VARIOUS	30/01/2022	Pass	0.052	-	-	>50	-	-	Pass	-	P
01103	ELSC1	ELSC1	VARIOUS	30/01/2022	Pass	0.055	-	-	>50	-	-	Pass	-	P
01105	CD PLAYER 0702	01105	VARIOUS	30/01/2022	Pass	-	-	-	>50	0	0.13	Skip	-	P
01106	CD PLAYER	CD PLAYER 79SUX	VARIOUS	30/01/2022	Pass	-	-	-	>50	0	0	Skip	-	P
01107	HP TOWER	TOWER	VARIOUS	30/01/2022	Pass	0.041	-	-	>50	0.013	0.26	Skip	-	P
01108	MONITOR	PINK	VARIOUS	30/01/2022	Pass	-	-	-	>50	0.036	0.1	Skip	-	P
01109	MIXER	0277	VARIOUS	30/01/2022	Pass	0.054	-	-	>50	0	0	Skip	-	P
01110	EL1X6	EL1X6	VARIOUS	30/01/2022	Pass	0.108	0.101	0.101	>50	-	-	Pass	-	P
01111	ELSCI04	ELSC1	VARIOUS	30/01/2022	Pass	0.065	-	-	>50	-	-	Pass	-	P
01102	MIC LEAD	M1102	VARIOUS	30/01/2022	Pass	-	-	-	-	-	-	Pass	-	P
01112	MIC LEAD	M1112	VARIOUS	30/01/2022	Pass	-	-	-	-	-	-	Pass	-	P
01113	MIC LEAD	M1113	VARIOUS	30/01/2022	Pass	-	-	-	-	-	-	Pass	-	P
01114	MIC LEAD	M1114	VARIOUS	30/01/2022	Pass	-	-	-	-	-	-	Pass	-	P
01117	12m EXTENTION LEAD	RED RDC	VARIOUS	30/01/2022	Pass	0.049	-	-	>50	-	-	Skip	-	P
01118	ADVENT MONITOR	PINK	VARIOUS	30/01/2022	Pass	0.063	-	-	>50	-	-	Skip	-	P

CONTRACTOR DETAILS

PEERLESS GROUP
83 Castle Road
Weddington
Nuneaton
Warks
CV10 0EW

Tester Name Chris Peers
Qualifications C&G 2377
Position CEO

Signature

